

Certificate of Compliance

Certificate Number **060304-E205607**
Report Reference **E205607-May 14, 2004**
Issue Date **2004 June 3**

Page 1 of 2



**Underwriters
Laboratories Inc.**

Issued to: **CHINT GROUP CORP.**
CHINT INDUSTRIAL ZONE, WENZHOU
ZHEJIANG 325604 CHINA

*This is to certify that
representative samples of*



COMPONENT-AUXILIARY DEVICES
Models NP2, or NP4 followed by up to three numbers or letters

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety: **UL508 - Industrial Control Equipment**
CSA Standard C22.2 No. 14

Additional Information: **See addendum**

Only those products bearing the UL Recognized Component Marks for the U.S. and Canada should be considered as being covered by UL's Recognition and Follow-Up Service and meeting the appropriate U.S. and Canadian requirements.

The UL Recognized Component Mark for the U.S. generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark: , may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions. The UL Recognized Component Mark for Canada consists of the UL Recognized Mark for Canada:  and the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory.

Look for the UL Recognized Component Mark on the product

Issued by


Underwriter
Underwriters Laboratories Inc.

Reviewed by


Project Engineer
Underwriters Laboratories Inc.

Certificate of Compliance

Certificate Number 060304-E205607
Report Reference E205607-May 14, 2004
Issue Date 2004 June 3

Page 2 of 2



**Underwriters
Laboratories Inc.**

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

RATINGS:

A300

Q300

Environmental Rating : Open Type

Conditions of Acceptability

1. These devices should be used within their Recognized ratings as specified below.
2. Open type devices should be mounted in enclosures having adequate strength and thickness and in the intended manner and with acceptable spacings being provided.
3. The terminals are not suitable for field wiring. They are to be factory wired only and the suitability of the connection (including spacings between factory connectors) shall be determined.

