

Certificate of Compliance

Certificate: 1630348

Master Contract: 228580

Project: 1630348

Date Issued: June 7, 2005

Issued to: Zhejiang Chint Electrics Co., Ltd.
Chint High-Tech Industrial Zone
North Baixiang, Wenzhou
Zhejiang 325603
CHINA
Attention: Ms. Daisy She

The products listed below are eligible to bear the CSA Mark shown



Issued by: Sebastian George, P. Eng.



Fred Mark, P. Eng.

Authorized by: Director Far East Operations

PRODUCTS

CLASS 3215 30 - Supplementary Protectors - Component Acceptance Program

Supplementary Protectors, overcurrent thermal magnetic type, General Industrial Use, Series NB1-63-C1, -C2, -C3, -C4, -C6, -C10, -C16, -C20, -C25, -C32, -C40, -C50 and -C63, trip rating at 175%, 1 to 4 poles, 40°C ambient, rated as below:

Maximum V	Maximum A	TC	OL	SC	Phase
277 V ac	1 to 63 A	2	0	5 KA	Single
480 V ac	1 to 63 A	2	0	5 KA	Three

Note: These protectors have been examined for use only as components in complete assemblies where the suitability of the combination is subject to further investigation.

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 235 - 04 - Supplementary Protectors