




CERTIFICATE FI 22727

Our Ref. 243193-3

Product	Residual current operated circuit-breakers
Type	NB1L-40
Trade mark	CHNT
Certificate Holder/ Manufacturer	Chint Group Corporation Zhengtai Bldg., Liushi Ind. Zone WENZHOU 325604 CHINA
Technical information	1-40 A, 230 or 400 V AC, $1_{\Delta n} = 0,03 \text{ A}$, 0,1 A or 0,3 A
Other information	2 poles 230 V AC, 4-poles 400 V AC, $1_{\Delta s} = 6000 \text{ A}$, $1_m = 1_{\Delta n} = 500 \text{ A}$, residual current operated circuit-breaker type A, circuit-breaker for overcurrent protection type C
The product is certified according to the following standard(s)	EN 61009-2-1:1994 + A1:1995 + A2:1998 + A11:1995 + A13:1998 + A14:1998 + A15:1998 + A17:1998 + A19:2000 EN 61009-1:1994 + A11:1998
Validity	This certificate is valid until 31 December 2011 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.
Directive information	The product(s) fulfils the essential safety requirements for CE conformity marking according to the Low Voltage Directive (73/23/EEC and 93/68/EEC) at the date of issue of the certificate.
Date of issue	20 June 2006
	SGS Fimko Ltd
Signature	 Timo Peltonen Specialist, Product Certification



This certificate has 1 appendix

Appendix to Certificate: 22727

Manufacturing site

Chint Group Corporation
Chint High-tec Ind. Zone
North Baixiang, Wenzhou
ZHEJIANG 325603
CHINA

Additional information

The product has certificate 306909 issued by SEMKO in accordance with the Nordic Certification Service system.