Certificate Number: 08262/0

energysafe VICTORIA

CERTIFICATE OF APPROVAL

This is to certify that Energy Safe Victoria, Australia has, in accordance with the Electricity Safety (Equipment) Regulations 1999, approved the prescribed electrical equipment described hereunder, for which application for approval has been made by-

NAME & ADDRESS: Zhejiang Chint Electrics Co.Ltd.
Chint High-tech Industrial Zone,
North Baixiang, Wenzhou,Zhejiang
PRC 325603

DESCRIPTION OF ELECTRICAL EQUIPMENT:

Residual Current Device, Trade Name "CHINT", Cat No(s).: NL1-63, NL1-40, NL1-25. 240 / 415 V, 63, 40 & 25 A, 2 P or 4 P, AC. 0.01A (only for In=25A,2P), 0.03A ,0.1,0.3A tripping current,
Type A and type AC, Inc=Ic=10000A,6000A.

Required Marking: V08262

Unless withdrawn for any reason, **this approval shall expire on 10/04/2013.**

Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, must be clearly and indelibly marked with the required marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Energy Safe Victoria prior to the equipment being supplied or offered for supply.

Notification must be given to Energy Safe Victoria of any change to the name or address of the holder of the certificate within 20 business days.

Under mutual recognition provisions this approval permits the abovementioned prescribed electrical equipment to be supplied or offered for supply in all States and Territories of Australia and New Zealand.

N. F. [illegible]

Energy Safe Victoria

DATE OF APPROVAL: 10/04/2008

Victoria The Place To Be